



Professional Service Industries, Inc.  
 16550 Scheer Blvd, Suite 1  
 Hudson, FL 34667  
 Eng Certificate Of Authorization 3684  
 Phone: (727) 868-9526  
 Fax: (727) 868-0094

**Report No: PTR:0390975-20-S3**

**Issue No: 1**

These test results apply only to the specific locations and materials noted and may not represent any other locations or elevations. This report may not be reproduced, except in full, without written permission by Professional Service Industries, Inc. If a non-compliance appears on this report, to the extent that the reported non-compliance impacts the project, the resolution is outside the PSI scope of engagement.

# Proctor Report


<b>Client:</b> LANG DEVELOPMENT C/O PASCO EXCAVATING LLC, 18744 COUNTYLINE RD SPRING HILL, FL 34610  <b>Project:</b> PASCO MINE SPRING HILL, FL	<b>CC:</b> BRENDA NEWBERRY MARA HUNT THERESA MCLAUGHLIN THOMAS LANG
---	--

Approved Signatory: James Kenney (Branch Manager)  
 Date of Issue: 11/7/2017

## Sample Details

<b>Sample ID:</b> 0390975-20-S3	<b>Date Sampled:</b> 10/31/2017
<b>Sampled By:</b> William Morrison	<b>Specification:</b> D422/T88 Part. Size Analysis (Set #1)
<b>Source:</b> NATURAL GROUND	<b>Material:</b> Pale Brown Silty SAND
<b>Sampling Method:</b>	<b>General Location:</b> US 41 MINE
<b>Location:</b> BOTTOM LAYER OF PIT MATERIAL	<b>Tested By:</b> William McGinn
<b>Date Tested:</b> 11/6/2017	

## Dry Density - Moisture Content Relationship



## Test Results

AASHTO T 180  
**Maximum Dry Density (lb/ft³): 111.8**  
**Optimum Moisture Content (%): 11.6**  
 Method: A

## Comments